

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No: 3240-1130:134 Page 1 of 1

CATEGORY: Duct Smoke Detector Housing/Base

LISTEE: *Honeywell International Inc., 1500 W. Dundee Rd., Arlington Heights IL 60004-1472
Contact: Bob Hodgson (847) 797-4403 Fax (847) 797-3664

DESIGN: Model 14506873-001 duct smoke detector housing. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instruction, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model designation, air velocity rating and UL label.

APPROVAL: Listed as a duct detector housing for use with separately listed compatible control units and Honeywell Model TC807A (CSFM Listing No. 7256-1130:123) or Model TC806A (CSFM Listing No. 7257-1130:116) smoke detectors. Suitable for use in ducts where the velocity is between 300 and 4000 ft./min.

XLf: 3240-1209:155

*Rev. 06-14-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 14, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager